

 mersi PT. MERSIFARMA TM. SUKABUMI-INDONESIA		LOGSHEET PEMELIHARAAN APAR												: 1 dari 1		
														No. Dokumen	HSE-LO/008.00	
														Tanggal Berlaku	07 JAN 2025	
Periode Pemeriksaan : Mei 2026																
Area	LOKASI	JENIS	ISI (Kg)	NO INVENTARIS	LIST PEMERIKSAAN									TGL. SERVICE	TGL. EXPIRED	KETERANGAN
					TABUNG	BERAT	TEKANAN TABUNG		SEGEL/ PIN	HANDLE	TUAS	SELA NG	NOZZEL			
							GREEN (V)	RED (X)								
RING I																
Loker Utama	Checking Body Perempuan	Powder	3,5	001/PLA/UM/APAR/VIII/14	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
Office Lantai 3	Koridor Lantai 3 (QC)	Powder	3,5	052/PLA/UM/APAR/V/20	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
Kantin & Kanser	Sisi Kanan DHP Frimal	Powder	3,5	021/PLA/UM/APAR/VIII/19	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
RING II																
Unit 1 Steril	R. Washing Vial Kelas D	Powder	3,5	011/PLA/UM/APAR/VIII/14	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
Workshop Engineering	Depan TPS LB3	Powder	3,5	006/PLA/UM/APAR/III/20	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
RING III																
Warehouse	R. Bahan Kemas Primer & Sekunder I	Powder	6	011/PLA/UM/APAR/I/19	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
	Rak 16 Lantai 1	Powder	3,5	049/PLA/UM/APAR/II/20	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
Unit 6B	Depan Pintu Lobby Bagian	CO2	3	016/PLA/UM/APAR/II/20	V	-	-	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
	Depan Pintu Ruang Antara	CO2	3	050/PLA/UM/APAR/V/20	V	-	-	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
	Koridor dalam samping R. Sterilisasi	Powder	3,5	007/PLA/UM/APAR/VIII/14	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
Unit 6A	Depan Pintu Emergency Exit	CO2	3	056/PLA/UM/APAR/V/20	V	-	-	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
	Samping Pintu Masuk Visitor	CO2	3	053/PLA/UM/APAR/V/20	V	-	-	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
	Koridor 6A	Powder	3,5	031/PLA/UM/APAR/II/20	V	-	V	-	-	V	V	V	V	27-May-24	27-May-26	EXPIRED
RING IV																
Area Utility	R. Genset 6 Ton	CO2	25	027/PLA/UM/APAR/II/20	V	-	-	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
	R. AHU Boiler 6 Ton	CO2	5	021/PLA/UM/APAR/II/20	V	-	-	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
Unit 2	Koridor dalam R. Kemas Sekunder	Powder	3,5	002/PLA/UM/APAR/I/19	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
	Depan R. Pengayakan	Powder	3,5	006/PLA/UM/APAR/I/19	V	-	V	-	V	V	V	V	V	28-May-24	27-May-26	EXPIRED
	Depan R. Pengemasan	Powder	3,5	012/PLA/UM/APAR/VIII/14	V	-	V	-	V	V	V	V	V	29-May-24	27-May-26	EXPIRED
	Depan Toilet Pria Lt 2	Powder	3,5	025/PLA/UM/APAR/X/11	V	-	V	-	V	V	V	V	V	30-May-24	27-May-26	EXPIRED
	Samping R. Sampling Lt 2	Powder	3,5	008/PLA/UM/APAR/I/19	V	-	V	-	V	V	V	V	V	31-May-24	27-May-26	EXPIRED
	Kontainer 12	Powder	3,5	003/PLA/UM/APAR/I/19	V	-	V	-	V	V	V	V	V	24-Jan-25	24-Jan-25	EXPIRED
	Area Cutting	CO2	5	048/PLA/UM/APAR/II/20	V	-	-	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
Kontainer Project	Area Cruher	CO2	5	022/PLA/UM/APAR/II/20	V	-	-	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
Kontainer 9 (Backup)	Kontainer 9	CO2	7	060/PLA/UM/APAR/V/20	V	-	-	-	V	V	V	V	V	10-Jan-25	10-Jan-26	EXPIRED
	Kontainer 9	CO2	7	025/PLA/UM/APAR/II/20	V	-	-	-	V	V	V	V	V	10-Jan-24	10-Jan-24	EXPIRED
	Kontainer 9	CO2	3	062/PLA/UM/APAR/V/20	V	-	-	-	V	V	V	V	V	8-May-21	8-May-23	EXPIRED
	Kontainer 9	Powder	3,5	022/PLA/UM/APAR/VIII/19	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
	Kontainer 9	Powder	3,5	017/PLA/UM/APAR/VIII/14	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	LOW PRES & EXPIRED
	Kontainer 9	Powder	3,5	009/PLA/UM/APAR/II/20	V	-	V	-	V	V	V	V	V	27-May-24	27-May-26	LOW PRES & EXPIRED
	Kontainer 9	Powder	6	043/PLA/UM/APAR/II/20	V	-	-	V	-	V	V	V	V	10-Aug-23	10-Aug-25	LOW PRES & EXPIRED
	Kontainer 9	Powder	6	045/PLA/UM/APAR/X/11	V	-	-	V	-	V	V	V	V	10-Aug-23	10-Aug-25	LOW PRES & EXPIRED
	Unit 2 Lab Kimia	CO2	3	055/PLA/UM/APAR/V/20	V	-	-	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED
	Unit 2 Lab Kimia	CO2	3	010/PLA/UM/APAR/I/19	V	-	-	-	V	V	V	V	V	27-May-24	28-May-26	EXPIRED
WTS Unit 6B	CO2	5	051/PLA/UM/APAR/V/20	V	-	-	-	V	V	V	V	V	27-May-24	27-May-26	EXPIRED	
Kontainer 9	CO2	7	061/PLA/UM/APAR/V/20	V	-	-	-	V	V	V	V	V	10-Jun-24	10-Jun-26	EXPIRED	

Jenis	Isi	Jumlah	Satuan
Powder	3	0	Tabung
Powder	3.5	17	Tabung
Powder	6	0	Tabung
Powder	25	0	Tabung
Total Powder		17	Tabung
CO2	3	0	Tabung
CO2	5	0	Tabung
CO2	7	0	Tabung
CO2	25	0	Tabung
Total CO2		0	Tabung

Area	LOKASI	JENIS	ISI (Kg)	NO INVENTARIS	LIST PEMERIKSAAN								TGL. SERVICE	TGL. EXPIRED	KETERANGAN	
					TABUNG	BERAT	TEKANAN TABUNG		SEGEL/ PIN	HANDLE	TUAS	SELANG				NOZZEL
							GREEN (V)	RED (X)								
Total Keseluruhan		17	Tabung													