

 mersi PT. MERSIFARMA TM DIVISI MANUFACTURING SUKABUMI - INDONESIA		KARTU STOCK BARANG / ALAT			Form No : 2QA00/FORM/017.00 Tgl. Berlaku 24 November 2010 Dibuat oleh NLI			
Nama Barang / Alat : <u>Nitrogen @ 6 m³</u>								
Kode Barang : <u>IMO14061</u>								
Manufactur / Supplier : <u>PT. Samator Gas Industri</u>								
Satuan Tabung								
No	Tgl	Stok awal	Jumlah			Stok akhir	Keterangan	Prf.
			Penerimaan	Pengeluaran	Rusak/aus			
10	04/21/2025	2		1		1	U.4 Perbaikan outdoor Z.1 No. 1 (4x test press)	Adiansyah
11	05/05/2025	1		1		0	Test press IOT	Adiansyah
12	18/07/2025		3			3	Kedatangan	
13	19/07/2025	3		1		2	1). Perbaikan outdoor Z.1,2, ekspansi 2 U.1NS 2). Test press 200 PSI (cek kebocoran) 3). Flushing 4). Test press 200 PSI (cek kebocoran setelah pengelasan)	Adiansyah
14	09/08/2025	2		1		1	1). Perbaikan outdoor Z.1,ekspansi 1 U.1NS 2). Test press 200 PSI (cek kebocoran) 3). Flushing 4). Test press 200 PSI (cek kebocoran setelah pengelasan)	Adiansyah
15	22/09/2025	1	2			3	Kedatangan	
16	22/09/2025	3		1		2	1). Perbaikan outdoor z.4 U.4 2). Perbaikan AC split & AC standing kasner 3). Perbaikan outdoor Z.6 No. 1 U.4	Adiansyah
17	24/10/2025	2		1		1	1). Perbaikan outdoor z.5 U.4	Adiansyah
18	29/10/2025	1		1		0	1). Perbaikan cold storage 1 NO. 1	Adiansyah
19	04/11/2025	0	2			2	Kedatangan	
20	08/11/2025	2		1		1	1). Perbaikan AC cassete R. pertinggal Lt. 3 2). Perbaikan AC cassete R. pertinggal Lt. 2	Ikhsan
21	01/12/2025	1		1		0	1). Perbaikan AC split	Ikhsan
22	21/01/2026	0	3			3		
23	05/03/2026	3		1		2	1. Perbaik U.2 zona 4 compressor 1 (flasing & test press 2. 1. Zona 2 outdoor 1 (test press	Sopian
24	10/03/2026	2		1		1	1. U.3 penambahan AHU: flusing 2 outdoor	Asep Suryana
25	13/04/2026	1		1		0	1. U.3 penambahan AHU: flusing 2 outdoor	Asep Suryana
26	28/05/2026	0	5			5	Kedatangan	

