

 mersi <i>Good Quality Improves Life's Quality</i> PT. MERSIFARMA TM. SUKABUMI-INDONESIA	CONSUMABLE JUSTIFICATIONS	Nomor : Tanggal : 17 Juli 2024 Revisi : 01
--	--------------------------------------	--

NAMA BARANG	Freon
TYPE / BRAND	R410 A
PACKAGING ORIGINAL	1 Tabung @ 10 Kg
PEMBELIAN	Lokal
DIGUNAKAN UNTUK	Out Door HVAC, Out Door Chiller dan Out Door AC Splt

Estimasi Jumlah Pemakaian

- A. Digunakan untuk penambahan dan perbaikan kebocoran outdoor HVAC yang menggunakan Freon R410 A
- Freon R410 A setiap 0,1 Kg digunakan untuk perbaikan / Penambahan Freon selama 1 bulan, pada 1 Out door HVAC atau chiller.
 - Freon R410 A setiap 0,05 Kg digunakan untuk pekerjaan selama 1 bulan, pada 1 Out door AC Split, Berikut daftar kebutuhan perbulan Freon R410 A.

No.	Lokasi Out Door	Jumlah Out Door [A]	Freon R22 / Bulan [B]	Total [A x B]
1	HVAC Lab. Mikro Zona 1	2	0,1	0,2
2	HVAC Lab. Mikro Zona 2	2	0,1	0,2
3	HVAC U.2 Zona 1	3	0,1	0,3
4	HVAC U.2 Zona 2	2	0,1	0,2
5	HVAC U.2 Zona 3	2	0,1	0,2
6	HVAC U.2 Zona 4	2	0,1	0,2
7	HVAC U.2 Zona 5	2	0,1	0,2
8	HVAC U.3 Zona 2	2	0,1	0,2
9	U.6A Chiller 1	2	0,1	0,2
10	U.6A Chiller 2	2	0,1	0,2
11	U.6A Chiller 3	2	0,1	0,2
12	U.6A Chiller 4	2	0,1	0,2
13	U.6A Chiller 5	2	0,1	0,2
14	U.6A Chiller 6	2	0,1	0,2
15	U.6A Chiller 7	2	0,1	0,2
16	U.6A Chiller 8	2	0,1	0,2
17	U.6A Chiller 9	2	0,1	0,2
18	U.6A Chiller 10	2	0,1	0,2
19	U.6A Chiller 11	2	0,1	0,2

20	U.6A Chiller 12	2	0,1	0,2
21	U.6B Chiller 1	2	0,1	0,2
22	U.6B Chiller 2	2	0,1	0,2
23	U.6B Chiller 3	2	0,1	0,2
24	U.6B Chiller 4	2	0,1	0,2
25	U.6B Chiller 5	2	0,1	0,2
26	U.6B Chiller 6	2	0,1	0,2
27	U.6B Chiller 7	2	0,1	0,2
28	AC Split U1	5	0,05	0,25
29	AC Split U.1 Steril	1	0,05	0,05
30	AC Split U.2	1	0,05	0,05
31	AC Split U.3	2	0,05	0,1
32	AC Split U.4	5	0,05	0,25
33	AC Split U.5	1	0,05	0,05
34	AC Split Kantor Office	6	0,05	0,3
35	AC Split Kanser	1	0,05	0,05
36	AC Split Mess	17	0,05	0,85
37	AC Split Office Engineering	5	0,05	0,25
38	AC Split Kontainer	6	0,05	0,3
39	AC Split Gudang Sentral	5	0,05	0,25
Total Kebutuhan Freon R410 A / Bulan				8,2 Kg = 1 Tabung

Lead Time

: 2 Bulan SPB

C. Decide to maintain
minimal stock

: [Total Kebutuhan Freon R410A / Bulan x Lead Time]

[1 x 2] = 2 Tabung

(Back UP Perbaikan 2 Outdoor HVAC [Pengisian Ulang])

D. Decide to maintain


: [C x 150%]

Order Quantity (100% - 150%)

[2 x 150%] = 3 Tabung

PROPOSAL TO SECURE OF SUPPLY

MINIMUM STOCK	ORDER QUANTITY
2	3

Di Susun Oleh	Diperiksa		Mengetahui
 Ahsanul 17/24 07	 Supervisor Compliance	 Assistant Manager	 Engineering Manager